



Mr. Russ Scharlin, PE  
Environmental Soil Stabilization, LLC  
4025 Woodland Park Blvd., Suite 165  
Arlington, TX 76013-4377

January 28, 2005

**Subject: Update on Expansive Soil Remediation**  
North Las Vegas, Nevada

**Reference: Remediation of Expansive Soils**  
Letter by TerraPacific Consultants, dated April 7, 2003


Dear Mr. Scharlin:

As requested, I am happy to provide this update on 15 homes in North Las Vegas that were impacted by expansive soil and subsequently stabilized by EcSS 3000 electrochemical in early 2002. Remember, this repair included perimeter injection at the exterior foundation of all 15 homes and port injection through the interior slab (1 case).

Although we have revisited other homes in this subdivision having different repairs (cut-off walls, etc.), we have not been called back to any of the chemically stabilized homes since our monitoring period ended in 2003. Therefore, we are unable to comment on geotechnical performance over the past 18 months; except to say that "no call backs" is an encouraging sign that problems of the past are now behind us.

We will make a note to contact you if any contrary information is brought to our attention.

Respectfully submitted,  
TerraPacific Consultants



Kevin M. Jordan, PE, GE  
President/Principal Engineer